



CERTIFICATE OF CONFORMITY

KJ6359

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation at

Adactus Housing Group
Butler Court Review, Manchester, M40 7WU

It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

Certificated Contractor

Firetech UK Ltd
Unit 12, Windrush Millennium Centre
70 Alexandra Road
Manchester
M16 7WD

Signed for and on behalf of Firetech UK Ltd

Anthony Allcock
Employee

Issue Date: 13/03/2017

Page 1 of 3





FIRAS Certificate of Conformity - KJ6359

Installation Details

Page 2 of 3

| | |
|---|--|
| Installation Address | Adactus Housing Group Butler Court Review Manchester M40 7WU |
| Completion Date | 14/03/2017 |
| Job Reference | Butler Court |
| Scope of Job | Refurbishment |
| Products Types Used | Penetration Sealing |
| Contractors Quality Control | All fire barriers by Firetech have been identified with sequentially numbered firestop labels and recorded on the attached firestopping schedules. |
| Items outside scope of work of Installation Company and exceptions | Any works not identified with a Firetech sequentially numbered firestop label. |
| TO ENSURE CONTINUED CONFORMANCE, THIS INSTALLATION SHOULD BE SUBJECT TO ONGOING INSPECTION & MAINTENANCE | |

Certificated Contractor Details

| | |
|----------------------------|--|
| Company Name and Address | Firetech UK Ltd Unit 12, Windrush Millennium Centre 70 Alexandra Road Manchester M16 7WD |
| FIRAS Certification Number | KU7404 |
| Telephone | 0161 636 7542 |
| Name of Signatory | Anthony Allcock (Employee) |
| FIRAS ID | T40207 |
| Certificate Issue Date | 13/03/2017 |
| Signature | |

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation. It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

This Certificate only covers work carried out up to the date of issue. Fire protection measures can be degraded over time and it is the legal responsibility of the 'Responsible Person' to ensure that fire protection must be adequately maintained and repaired/replaced over the life of the building. For details on how to carry out a risk assessment to the requirements of the Regulatory Reform (Fire Safety) Order, please contact FIRAS on 01925 646666.



FIRAS Certificate of Conformity - KJ6359

Penetration Sealing Details

Page 3 of 3

| Manufacturer | Product | Fire Resistance |
|--------------|----------------------|-----------------|
| Rockwool | Ablative Coated Batt | 60 minutes |
| Rockwool | Intumescent Mastic | 60 minutes |