



---

## **CERTIFICATE OF CONFORMITY**

### **TM4315**

---

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation at

**Adactus Housing Group**  
Naylor Court Review, Manchester, M40 7WS

It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

---

#### **Certificated Contractor**

Firetech UK Ltd  
Unit 12, Windrush Millennium Centre  
70 Alexandra Road  
Manchester  
M16 7WD

Signed for and on behalf of Firetech UK Ltd

Anthony Allcock  
Employee

Issue Date: 13/03/2017

Page 1 of 3





## FIRAS Certificate of Conformity - TM4315

### Installation Details

Page 2 of 3

Installation Address	Adactus Housing Group Naylor Court Review Manchester M40 7WS
Completion Date	14/03/2017
Job Reference	Naylor Court
Scope of Job	Refurbishment
Products Types Used	Penetration Sealing
Contractors Quality Control	All fire barriers by Firetech have been identified with sequentially numbered firestop labels and recorded on the attached firestopping schedules.
Items outside scope of work of Installation Company and exceptions	Any works not identified with a Firetech sequentially numbered firestop label.
<b>TO ENSURE CONTINUED CONFORMANCE, THIS INSTALLATION SHOULD BE SUBJECT TO ONGOING INSPECTION &amp; MAINTENANCE</b>	

### Certificated Contractor Details

Company Name and Address	Firetech UK Ltd Unit 12, Windrush Millennium Centre 70 Alexandra Road Manchester M16 7WD
FIRAS Certification Number	KU7404
Telephone	0161 636 7542
Name of Signatory	Anthony Allcock (Employee)
FIRAS ID	T40207
Certificate Issue Date	13/03/2017
Signature	

This Certificate is issued by the certificated contractor in accordance with the FIRAS Certification Scheme's Regulations and Procedures to indicate the compliance of a fire resistant installation. It confirms that the project has been completed having full regards to the requirements of the appropriate product specification and its installation/application instructions and that the claimed performance is substantiated by appropriate test and/or assessment evidence.

This Certificate only covers work carried out up to the date of issue. Fire protection measures can be degraded over time and it is the legal responsibility of the 'Responsible Person' to ensure that fire protection must be adequately maintained and repaired/replaced over the life of the building. For details on how to carry out a risk assessment to the requirements of the Regulatory Reform (Fire Safety) Order, please contact FIRAS on 01925 646666.



## FIRAS Certificate of Conformity - TM4315

### Penetration Sealing Details

Page 3 of 3

Manufacturer	Product	Fire Resistance
Rockwool	Ablative Coated Batt	60 minutes
Rockwool	Intumescent Mastic	60 minutes